



GENERAL NOTES

Recycled Water

Also referred to as Reclaimed Water

1. Owner shall comply with the “Reclaimed Water User Agreement” with Mesa Consolidated Water District (Mesa), which incorporates Mesa’s Rules and Regulations for Reclaimed Water Service.
2. It shall be the responsibility of Owner to ensure that all operations personnel are trained in and familiarized with the use of Recycled Water, and are familiar with Mesa’s Rules and Regulations for Reclaimed Water Service. A copy of Mesa’s Rules and Regulations shall be kept on site at all times.
3. The operation and surveillance of the onsite Recycled Water system shall be under the management of the onsite supervisor designated by Owner and approved by Mesa.
4. Recycled Water service area shall be restricted to those areas explicitly approved by Mesa and the County Health Department.
5. All Recycled Water irrigation sprinkler heads shall be adjusted by Owner to eliminate overspray onto non-landscaped areas including but not limited to buildings, sidewalks, parking lots, and roads.
6. Irrigation shall be done in a manner that will minimize runoff pooling and ponding.
7. Cross-connections between the Recycled Water system and the Potable Water system are strictly prohibited.
8. Hose bibbs on the Recycled Water system are strictly prohibited.
9. The operation of the Recycled Water system shall be during periods of minimal use of the Recycled Water service area by the general public.
10. Owner must obtain prior approval for all proposed changes and modifications to any onsite facilities including modifying the Recycled Water service area.
11. Prior to connecting the onsite Recycled Water system to the Recycled Water service connection, a cross-connection control test and operational test shall be performed. The cross-connection control test shall be conducted by Mesa, Orange County Water District (OCWD), and the local Health Agency, and shall consist of shutting down the onsite Potable and Recycled Water systems to confirm the physical separation of the Recycled Water system from the Potable Water system. The exact testing procedures will be developed by Mesa. The operational test shall consist of a coverage test of the onsite Recycled Water irrigation system to ensure that the overspray and runoff is controlled.